

Appendix H - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

KTD1a - Centre of Excellence in Paediatrics (Children's Hospital)						
Date	Time	Weather	Unit: dB (A) (30-min)			
			Measured Noise Level			Baseline Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}
3-Apr-20	15:20	Cloudy	71	72	67	78
9-Apr-20	09:00	Fine	69	70	66	78
15-Apr-20	09:08	Fine	69	72	66	78
21-Apr-20	10:47	Sunny	68	70	65	78
27-Apr-20	09:30	Sunny	68	71	63	78

KTD2b - G/IC Zone next to Kwun Tong Bypass (Next to the site of the New Acute Hospital) / KTD 2c: G/IC Zone next to Kwun Tong Bypass (Next to the Kowloon Bay Sewage Interception Station)						
Date	Time	Weather	Unit: dB (A) (30-min)			
			Measured Noise Level			Baseline Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}
3-Apr-20	15:59	Cloudy	68	70	64	64
9-Apr-20	10:31	Fine	75	76	72	64
15-Apr-20	10:43	Fine	73	74	71	64
21-Apr-20	09:51	Sunny	70	72	66	64
27-Apr-20	11:04	Sunny	68	69	67	64

KER1b - Site Boundary at Cheung Yip Street						
Date	Time	Weather	Unit: dB (A) (30-min)			
			Measured Noise Level			Baseline Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}
3-Apr-20	14:45	Cloudy	69	72	66	65
9-Apr-20	09:42	Fine	71	72	66	65
15-Apr-20	09:48	Fine	74	79	70	65
21-Apr-20	11:26	Sunny	68	69	67	65
27-Apr-20	10:12	Sunny	72	75	69	65




Appendix H - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CKL1 - Flat 121 Cha Kwo Ling Village						
Date	Time	Weather	Unit: dB (A) (30-min)			
			Measured Noise Level			Baseline Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}
27-Apr-20	14:00	Sunny	68.9	71.6	63.6	72.4



Location CKL2 - Flat 103 Cha Kwo Ling Village						
Date	Time	Weather	Unit: dB (A) (30-min)			
			Measured Noise Level			Baseline Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}
27-Apr-20	14:50	Sunny	67.7	70.5	54.7	71.4

Noise Levels



Title Contract No. ED/2018/04 - Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Date Apr 20	Project No. MA20003	CINOTECH
		Appendix H	

Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Date	Project	CINOTECH
	Apr 20	No. MA20003	
		Appendix H	