

Appendix H - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CKL1 - Flat 121 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3-Dec-20	16:10	Sunny	73.8	76.8	62.9	72.4	68
9-Dec-20	16:45	Cloudy	73.1	76.4	63.2	72.4	65
18-Dec-20	13:00	Cloudy	68.5	71.8	57.1	72.4	68.5 Measured ≤ Baseline
21-Dec-20	15:50	Sunny	73.8	77.1	61.5	72.4	68
30-Dec-20	13:30	Sunny	69.9	72.5	60.7	72.4	69.9 Measured ≤ Baseline

Location CKL2 - Flat 103 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3-Dec-20	16:55	Sunny	72.6	76.6	63.8	71.4	66.4
9-Dec-20	17:20	Cloudy	71.7	75.1	62.8	71.4	59.9
18-Dec-20	13:00	Cloudy	71.8	75.0	62.0	71.4	61.2
21-Dec-20	16:30	Sunny	73.6	77.3	60.6	71.4	69.6
30-Dec-20	13:00	Sunny	70.4	74.0	60.9	71.4	70.4 Measured ≤ Baseline

Appendix H - Noise Monitoring Results



(0700-1900 hrs on Normal Weekdays)

Location KTD1 - Centre of Excellence in Paediatrics (Rooftop of Children's Hospital)							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3-Dec-20	11:00	Sunny	70.1	70.9	69.0	78.0	70.1 Measured ≤ Baseline
9-Dec-20	15:00	Cloudy	72.6	77.2	67.1	78.0	72.6 Measured ≤ Baseline
15-Dec-20	11:30	Fine	66.0	67.5	64.3	78.0	66 Measured ≤ Baseline
21-Dec-20	14:20	Sunny	70.8	72.6	69.1	78.0	70.8 Measured ≤ Baseline
30-Dec-20	15:40	Sunny	71.1	72.8	69.5	78.0	71.1 Measured ≤ Baseline

Location KTD2c - G/C Zone next to Kwun Tong Bypass (Next to the Kowloon Bay Sewage Interception Station)							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3-Dec-20	11:00	Sunny	74.2	75.7	71.3	64.0	74
9-Dec-20	13:50	Cloudy	74.1	75.0	73.1	64.0	74
15-Dec-20	11:00	Fine	68.2	69.8	65.6	64.0	66
21-Dec-20	13:15	Sunny	74.0	75.7	71.1	64.0	74
30-Dec-20	16:35	Sunny	75.1	80.4	64.8	64.0	75




Location KER1 - Future Residential Development at Kerry Godown							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3-Dec-20	13:00	Sunny	73.3	75.4	69.4	65.0	73
9-Dec-20	15:40	Cloudy	73.5	76.8	64.6	65.0	73
15-Dec-20	13:00	Fine	70.8	70.9	68.5	65.0	69
21-Dec-20	11:30	Sunny	73.4	76.5	68.8	65.0	73
30-Dec-20	14:45	Sunny	89.4	93.6	69.5	65.0	89

Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Date	Project	CINOTECH
	Dec 20	No. MA20003 Appendix H	

Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Date	Project	CINOTECH
	Dec 20	No. MA20003 Appendix H	