

Appendix H - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CKL1 - Flat 121 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
8-May-25	11:07	Cloudy	73.3	77.0	63.5	72.4	66
14-May-25	9:50	Sunny	74.3	78.2	62.0	72.4	70
20-May-25	14:00	Sunny	68.6	72.1	58.6	72.4	68.6 Measured \leq Baseline
26-May-25	11:52	Fine	75.9	80.0	61.2	72.4	73



Location CKL2 - Flat 103 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
8-May-25	11:38	Cloudy	75.6	79.6	61.2	71.4	74
14-May-25	10:20	Sunny	71.5	75.0	61.4	71.4	55
20-May-25	13:00	Sunny	72.6	76.1	61.7	71.4	66
26-May-25	11:24	Fine	75.7	79.7	60.0	71.4	74


Location KTD1 - Centre of Excellence in Paediatrics (Rooftop of Children's Hospital)							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
8-May-25	14:14	Sunny	71.0	72.2	69.4	78.0	71 Measured \leq Baseline
14-May-25	13:00	Sunny	70.7	72.6	68.4	78.0	70.7 Measured \leq Baseline
20-May-25	9:00	Sunny	71.9	74.2	69.2	78.0	71.9 Measured \leq Baseline
26-May-25	14:34	Fine	69.9	71.2	68.3	78.0	69.9 Measured \leq Baseline

Location KER1 - Future Residential Development at Kerry Godown							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
8-May-25	13:30	Cloudy	71.6	74.6	66.0	65.0	71
14-May-25	12:15	Fine	68.8	69.2	67.9	65.0	66
20-May-25	10:00	Sunny	74.4	75.4	72.7	65.0	74
26-May-25	13:51	Fine	69.0	70.9	65.5	65.0	67


Location KTD2d - Next to the SOR Office of Trunk Road T2 in Kai Tak Area							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
8-May-25	15:28	Cloudy	64.8	67.9	56.7	64.0	57
14-May-25	14:00	Fine	61.7	63.3	57.9	64.0	62 Measured \leq Baseline
20-May-25	11:00	Sunny	58.2	60.5	54.1	64.0	58 Measured \leq Baseline
26-May-25	15:35	Fine	62.3	64.4	58.4	64.0	62 Measured \leq Baseline


Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Date May 25	Project No. MA20003	
		Appendix H	

Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Date May 25	Project No. MA20003	
		Appendix H	