

## Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CM1 - Nga Lai House, Yau Lai Estate Phase 1, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
5 May 2021	18:15	Fine	64.7	66.1	63.2	65.5	65 Measured $\leq$ Baseline
11 May 2021	9:45	Sunny	72.8	74.5	70.1	65.5	72
17 May 2021	9:45	Sunny	72.9	75.3	69.6	65.5	72
26 May 2021	16:45	Sunny	71.1	74.3	58.2	65.5	70


Location CM2 - Bik Lai House, Yau Lai Estate Phase 1, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
5 May 2021	18:00	Fine	66.9	68.3	65.3	63.6	64
11 May 2021	9:00	Fine	72.2	74.8	69.5	63.6	72
17 May 2021	9:00	Sunny	73.1	75.4	69.9	63.6	73
26 May 2021	16:00	Sunny	70.2	73.4	68.1	63.6	69

Location CM3 - Block S, Yau Lai Estate Phase 5, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
5 May 2021	18:30	Fine	65.4	66.7	63.7	65.6	65 Measured $\leq$ Baseline
11 May 2021	10:30	Sunny	73.7	75.6	71.4	65.6	73
17 May 2021	10:30	Sunny	73.3	75.7	70.1	65.6	72
26 May 2021	17:30	Sunny	70.2	73.4	67.3	65.6	68

Location CM4 - Tin Hau Temple, Cha Kwo Ling							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
5 May 2021	13:15	Sunny	60.9	63.5	55.0	62.0	61 Measured $\leq$ Baseline
11 May 2021	13:00	Sunny	65.7	66.9	62.7	62.0	63
17 May 2021	14:00	Sunny	60.7	63.2	58.0	62.0	61 Measured $\leq$ Baseline
26 May 2021	9:00	Sunny	67.2	69.8	64.3	62.0	66


Location CM5 - CCC Kei Faat Primary School, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
5 May 2021	17:00	Fine	66.1	67.7	59.8	68.2	66 Measured $\leq$ Baseline
11 May 2021	11:30	Sunny	64.3	67.2	61.7	68.2	64 Measured $\leq$ Baseline
17 May 2021	11:30	Sunny	62.0	64.3	60.7	68.2	62 Measured $\leq$ Baseline
26 May 2021	14:00	Sunny	61.8	64.7	58.7	68.2	62 Measured $\leq$ Baseline

## Noise Levels



Title	Contract No. ED/2018/04	Scale	Project	CINOTECH
	Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron	N.T.S	No. MA20003	
Graphical Presentation of Construction Noise Monitoring Results		Date	Appendix	
		May 21	G	

## Noise Levels



**Notes:**

1. The major activitie(s) being carried out on site during the reporting period is/are presented in Section 1.10
2. The weather conditions during the reporting month are presented in Appendix C.
3. Other factors which might affect the monitoring results are presented in Section 3.13.

Title	Contract No. ED/2018/04		Scale	Project	
	Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron		N.T.S	No.	MA20003
	Graphical Presentation of Construction Noise Monitoring Results		Date	Appendix	G
			May 21		

**CINOTECH**