

## Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CM1 - Nga Lai House, Yau Lai Estate Phase 1, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
7 Jul 2021	12:00	Cloudy	67.1	68.1	66.0	65.5	62
13 Jul 2021	9:00	Sunny	70.6	73.5	66.4	65.5	69
19 Jul 2021	14:00	Rainy	68.5	70.6	66.3	65.5	65
29 Jul 2021	14:30	Cloudy	71.8	73.5	69.3	65.5	71


Location CM2 - Bik Lai House, Yau Lai Estate Phase 1, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
7 Jul 2021	11:30	Cloudy	69.3	70.4	68.0	63.6	68
13 Jul 2021	11:00	Sunny	70.4	72.4	68.2	63.6	69
19 Jul 2021	15:30	Rainy	69.7	71.0	68.1	63.6	68
29 Jul 2021	13:30	Cloudy	72.3	75.3	68.9	63.6	72

Location CM3 - Block S, Yau Lai Estate Phase 5, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
7 Jul 2021	13:30	Cloudy	71.2	73.1	68.7	65.6	70
13 Jul 2021	10:00	Sunny	67.6	67.9	67.4	65.6	63
19 Jul 2021	14:45	Rainy	70.6	70.9	70.4	65.6	69
29 Jul 2021	14:40	Cloudy	72.7	74.7	70.1	65.6	72

Location CM4 - Tin Hau Temple, Cha Kwo Ling							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
7 Jul 2021	10:40	Cloudy	64.5	68.0	58.9	62.0	61
13 Jul 2021	2:00	Sunny	70.7	70.9	70.4	62.0	70
19 Jul 2021	16:10	Rainy	64.8	67.5	60.2	62.0	62
29 Jul 2021	10:30	Sunny	75.0	82.0	73.9	62.0	75


Location CM5 - CCC Kei Faat Primary School, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
7 Jul 2021	14:10	Cloudy	70.6	73.1	66.2	68.2	67
13 Jul 2021	13:00	Sunny	71.7	75.1	66.0	68.2	69
19 Jul 2021	16:00	Rainy	69.5	70.5	65.9	68.2	64
29 Jul 2021	11:40	Cloudy	68.6	71.1	64.3	68.2	58

## Noise Levels



<b>Title</b> Contract No. ED/2018/04 Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron  Graphical Presentation of Construction Noise Monitoring Results	<b>Scale</b> N.T.S	<b>Project</b> No. MA20003	
	<b>Date</b> Jul 21	<b>Appendix</b> G	

## Noise Levels



**Notes:**

1. The major activitie(s) being carried out on site during the reporting period is/are presented in Section 1.10
2. The weather conditions during the reporting month are presented in Appendix C.
3. Other factors which might affect the monitoring results are presented in Section 3.13.

Title	Contract No. ED/2018/04		Scale	Project	
	Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron		N.T.S	No. MA20003	
	Graphical Presentation of Construction Noise Monitoring Results		Date Jul 21	Appendix	G

**CINOTECH**